

Industrial Pulsers for T3000C Turbine Meters

Sizes: 1 1/2" - 12"



Materials:

Note: These units are NOT repairable.

Pulser Body	Plastic
Wire - LRP	2-wire shielded cable
Wire - HRP	3-wire shielded cable

Pulse Output:

LRP (Reed Switch Pusler) 2-wire

Size	US Gallon	Cubic Feet	Cubic Meter/Liters
1 1/2"-2"	1cont/gal	10cont/cf	1cont/10 liters
3"-4"	1cont/10 gal	1cont/cf	1cont/10 liters
6"-8"	1cont/10 gal	1cont/cf	1cont/100 liters
10"-12"	1cont/100 gal	1cont/10 cf	1cont/100 liters

HRP (Slotted Disc - Opto Vane Switch) 3-wire

Size	US Gallon	Cubic Feet	Cubic Meter/Liters
1 1/2"-2"	10cont/gal	100cont/cf	1cont/liter
3"-4"	1cont/gal	10cont/cf	1cont/liter
6"-8"	1cont/gal	10cont/cf	1cont/10 liters
10"-12"	1cont/10 gal	1cont/cf	1cont/10 liters

Note: When using the HRP pulser with the R420, a 12V Zener diode (1 watt rated) must be installed in series between the 24VDC output pin and the red (6-15VDC) power in wire. These diodes can be purchased at any Radio Shack.

Increase weight of the meter by 12 oz.
 Increase height dimension of the meter by 1.14"
 Normal height of pulsers = 1.46"

Description

LRP: (Reed Switch)
 HRP: (Slotted Disc - Opto Vane Switch)

These units are designed for use with T3000C with polymer top plate, bronze top plate (machined for pulser) and cast iron top plate. The meter will be produced with polymer top plate or cast iron top plate unless specified for bronze top plate.

These units are weatherproof with 9 to 10 ft. of 2-wire or 3-wire shielded cable exiting from an epoxy sealed case.

These pulsers are magnetically driven which eliminates miscoupling associated with right angle drives. Torque is absorbed in the undergear assembly in the meter, below the drive magnet. The drive magnet, at all flows, is turning slowly assuring magnetic coupling.

LRP : (Reed Switch) (2 wire)

The pulse element is a reed switch rated at 4 watts, non inductive, magnetically actuated to provide a 50/50 open/close ratio and requires power from an external source. Note: These units have a 100 ohm resistor in series with the reed switch to protect from current surges.

HRP : (Slotted Disc - Opto Vane Switch)

The transmitting element is a slotted disc and opto vane switch which requires power from an external source. Power requirement (6-15 VDC).



LRP Wiring Diagram (2-Wire) 4W Reed Switch



To be wired in series with no regard as to polarity.

HRP Wiring Diagram


Slotted Disc 6-15 VDC (3-Wire Shielded)
This unit is sourcing device

18 mA: Max Current Draw
10 mA: Nominal Current Draw




NOTE:


When using the HRP pulser with R-420, a 12 V Zener diode (1 watt rated) must be installed in series between 24 VDC out and the red (6-15 VDC) power in line.



Helix Low Profile



Helix High Profile



C701 Type

Elster AMCO Water, Inc.
 PO Box 1852
 Ocala, FL 34478-1852
 United States

T +1 800 874 0890
 F +1 352 368 1950

watermeters@us.elster.com
 www.elster.com

© 2007 by Elster. All rights reserved.

The company's policy is one of continuous product improvement and the right is reserved to modify the specifications contained herein without notice. These products have been manufactured with current technology and in accordance with applicable AWWA Standards.